

Joseph Lstiburek, Ph.D., P.Eng, ASHRAE Fellow

Building Science

Ventilation

www.buildingscience.com

“It isn't what we don't know that gives us trouble, it's what we know that ain't so”

Will Rogers


“There are known knowns. These are things we know. There are known unknowns. There are things that we know we don't know. But there are also unknown unknowns. There are things we don't know we don't know.





Donald Rumsfeld




Building Science Corporation Joseph Lstiburek 2





Lapse Rate





Building Science Corporation Joseph Lstiburek 3



































Duct Leakage Should Be Less Than 5% of Rated Flow As Tested By Pressurization To 25 Pascals





Building Science Corporation


Joseph Lstiburek – Airflow 35

















Figure 3.18
Insufficient Return Air Paths



- Pressurization of bedrooms often occurs if insufficient return pathways are provided; undercutting bedroom doors is usually insufficient; transfer grilles, jump ducts or fully ducted returns may be necessary to prevent pressurization of bedrooms
- Master bedroom suites are often the most pressurized as they typically receive the most supply air
- When bedrooms pressurized, common areas depressurize; this can have serious consequences when fireplaces are located in common areas and subsequently backdraft


A schematic diagram of a bedroom suite showing air flow. An 'Air handling unit' is located at the top. Air is supplied to two bedrooms (marked with '+') and a hall (marked with '-'). The return air from the bedrooms and hall is shown flowing back to the air handling unit. The diagram illustrates the flow of air from the supply to the return and back to the air handling unit.

Building Science Corporation
Joseph Lstiburek – Airflow 56














Air Barrier Metrics

Material	0.02 I/(s-m2)@75 Pa
Assembly	0.20 I/(s-m2)@75 Pa
Enclosure	2.00 I/(s-m2)@75 Pa

Building Science Corporation
Joseph Lstiburek 71





Flow Through Orifices
 Turbulent Flow - “inertial effects”

Flow Through Porous Media
 Laminar Flow - “viscosity effects”

Building Science Corporation Joseph Lstiburek – Airflow 77

Flow Through Orifices
 Turbulent Flow - “inertial effects”

Flow Through Porous Media
 Laminar Flow - “viscosity effects”

“true but not useful”

Building Science Corporation Joseph Lstiburek – Airflow 78

$$Q = A \cdot C_d \left[\frac{2}{\rho} (\Delta P) \right]^{\frac{1}{2}} \quad \text{Bernoulli}$$

$$Q = C_k \frac{\rho}{\mu} (\Delta P) \quad \text{Darcy}$$

Building Science Corporation Joseph Lstiburek – Airflow 79

$$Q = A \cdot C_d \left[\frac{2}{\rho} (\Delta P) \right]^{\frac{1}{2}} \quad \text{Bernoulli}$$

$$Q = C_k \frac{\rho}{\mu} (\Delta P) \quad \text{Darcy}$$

$$Q = A \cdot C (\Delta P)^{\frac{1}{2}}$$

$$Q = C (\Delta P)$$

Building Science Corporation Joseph Lstiburek – Airflow 80

$$Q = A \cdot C_d \left[\frac{2}{\rho} (\Delta P) \right]^{\frac{1}{2}} \quad \text{Bernoulli}$$

$$Q = C_K \frac{\rho}{\mu} (\Delta P) \quad \text{Darcy}$$

$$Q = A \cdot C (\Delta P)^{\frac{1}{2}}$$

$$Q = C (\Delta P)$$

$$Q = A \cdot C (\Delta P)^n \quad \text{Kronval "an engineer"}$$

Building Science Corporation Joseph Lstiburek – Airflow 81

Figure 2.5
Modes of Air Flow
(from Bumbaru, Jutras and Patenaude, 1988)

Building Science Corporation Joseph Lstiburek – Airflow 82





Figure 2.10
Resistance Network
(from Kronval, 1988)



1. Air permeating the wood-panel cladding
2. Air flow between floor slab and canal
3. Air flow between floor slab and wind protection
4. Air permeating the caulking
5. Air flow between wind protection and sill
6. Air flow between insulation material and sill
7. Air flow between inner lining and sill
8. Air flow between inner lining and floor slab
9. Air flow between tilt and inner lining
10. Air flow between tilt and floor slab



Building Science Corporation Joseph Lstiburek – Airflow 83




Figure 2.11
Three Dimensional Multi-Layer Multi-Cell Analogue





Building Science Corporation Joseph Lstiburek – Airflow 84



















Build Tight - Ventilate Right

Building Science Corporation Joseph Lstiburek 19

Build Tight - Ventilate Right
How Tight?
What's Right?

Building Science Corporation Joseph Lstiburek 20

Air Barrier Metrics

Material	0.02 l/(s-m ²) @ 75 Pa
Assembly	0.20 l/(s-m ²) @ 75 Pa
Enclosure	2.00 l/(s-m ²) @ 75 Pa
	0.35 cfm/ft ² @ 50 Pa
	0.25 cfm/ft ² @ 50 Pa
	0.15 cfm/ft ² @ 50 Pa

Building Science Corporation

Joseph Lstiburek 21

Getting rid of big holes	3 ach@50
Getting rid of smaller holes	1.5 ach@50
Getting German	0.6 ach@50

Building Science Corporation

Joseph Lstiburek 22

Best

As Tight as Possible - with -
 Balanced Ventilation
 Energy Recovery
 Distribution
 Source Control - Spot exhaust ventilation
 Filtration
 Material selection

Building Science Corporation

Joseph Lstiburek 23

Worst

Leaky - with – Nothing
 Spot Ventilation in Bathroom/Kitchen
 Exhaust Ventilation – with – No Distribution




Building Science Corporation





Joseph Lstiburek 24


Three Types of Controlled Ventilation Systems

- Exhaust Ventilation
- Supply Ventilation
- Balanced Ventilation

Building Science Corporation Joseph Lstiburek – HVAC 25







Building Science Corporation

Joseph Lstiburek 33

Cost	Exhaust	\$150
	Exhaust + Dist	\$200
	Supply + Dist	\$200
	Spot + Ex/Sup + Dist	\$500
	Balanced/HRV	\$1,250


Building Science Corporation

Joseph Lstiburek 34

The Cult of The Blower Door

Building Science Corporation

Joseph Lstiburek 35



Building Science Corporation

Joseph Lstiburek 36

Blower Door Can't Get You The True ACH
On A Short Term Basis – Hour, Day, Week

Building Science Corporation Joseph Lstiburek 37

Don't Know Where The Holes Are
Don't Know The Type of Holes
Don't Know The Pressure Across The Holes

Building Science Corporation Joseph Lstiburek 38

Good For Long Term Average If No Big
Pressures

Building Science Corporation Joseph Lstiburek 39

Good For Long Term Average If No Big
Pressures
Good For Average Annual Energy Prediction

Building Science Corporation Joseph Lstiburek 40

Good For Long Term Average If No Big Pressures
Good For Average Annual Energy Prediction
Not Good For IAQ Unless You Accept Average Annual Exposure As A Metric

Building Science Corporation Joseph Lstiburek 41

Cost of Addressing the Problems Are Less Than The Cost of Testing To See If You Have Problems

Building Science Corporation Joseph Lstiburek 42

Combustion Safety
Indoor Contaminants
Comfort
Energy




Building Science Corporation Joseph Lstiburek 43





Bring Combustion Appliances Up To Code
Control Pressures
Install Controlled Ventilation
Get Rid of Big Holes
Insulate




Building Science Corporation Joseph Lstiburek 44

Code Compliant Combustion Air

Building Science Corporation Joseph Lstiburek 45







Sealed Combustion Appliances


Building Science Corporation





Joseph Lstiburek 56






Control Pressures





Building Science Corporation
Joseph Lstiburek 59













































































Distributed Ventilation

- Individual unit exhaust ventilation fan exhausts (during occupancy) from each bedroom, bathroom, and kitchen
- Operation of system is time of occupancy sensitive — on only when occupied

Building Science Corporation Joseph Lstiburek 62





Ventilation Rates Are Based on Odor Control

Building Science Corporation Joseph Lstiburek 2

Ventilation Rates Are Based on Odor Control
Health Science Basis for Ventilation Rates is
Extremely Limited


Building Science Corporation Joseph Lstiburek 3

Ventilation Rates Are Based on Odor Control
Health Science Basis for Ventilation Rates is
Extremely Limited
Almost Nothing Cited Applies to Housing

Building Science Corporation Joseph Lstiburek 4

Ventilation Rates Are Based on Odor Control
Health Science Basis for Ventilation Rates is
Extremely Limited
Almost Nothing Cited Applies to Housing
The Applicable Studies Focus on Dampness

Building Science Corporation Joseph Lstiburek 5



Building Science Corporation

Joseph Lstiburek 6

House

**2,000 ft²
3 bedrooms
8 ft. ceiling
Volume: 16,000 ft³**

.35 ach	93 cfm
.30 ach	80 cfm
.25 ach	67 cfm
.20 ach	53 cfm
.15 ach	40 cfm

Building Science Corporation

Joseph Lstiburek 7

House

**2,000 ft²
3 bedrooms
8 ft. ceiling
Volume: 16,000 ft³**

.35 ach 93 cfm .30 ach 80 cfm .25 ach 67 cfm .20 ach 53 cfm .15 ach 40 cfm	Ventilation Rates		
	62 - 73	5 cfm/person	20 cfm
		10 cfm/person	40 cfm
	62 - 89	15 cfm/person	60 cfm
		.35 ach 90 cfm	
	62.2 - 2010	7.5 cfm/person	50 cfm
	+ 0.01		
	62.2 - 2013	7.5 cfm/person	90 cfm
	+ 0.03		

Building Science Corporation

Joseph Lstiburek 8

Office

Occupant Density

15/1000 ft ² (67 ft ² /person)	62 - 89	15 cfm/person
5/1000 ft ² (200 ft ² /person)	62.1 - 2007	17 cfm/person

Correctional Facility Cell

Occupant Density

20/1000 ft ² (48 ft ² /person)	62.1 - 2007	10 cfm/person
--	-------------	---------------

C.P. Yaglou
 Harvard School of Public Health
 1936
 1955



150 ft³ → 20 cfm/person approx 4x4x8
 300 ft³ → 12 cfm/person approx 6x6x8


C.P. Yaglou
 Harvard School of Public Health
 1936
 1955

150 ft³ → 20 cfm/person 18.75 ft² 106 occupants
 300 ft³ → 12 cfm/person 37.5 ft² 53 occupants

Experiment

470 ft³ → 59 ft²
 200 ft³ → 25 ft²
 100 ft³ → 12 ft²





Dilution is Not The Solution To Indoor Pollution

Building Science Corporation Joseph Lstiburek 15




Table 1. Summary of the air changes rates measured during the winter 2009-10 season in Quebec City

Method	ACH (h ⁻¹)	ACH standard deviation (h ⁻¹)	number of measurements
SF ₆ tracer decay	0.27	0.12	77
perfluorocarbon tracer	0.32	0.22	37
blower door at 50 Pa	4.16	2.64	63

Building Science Corporation Joseph Lstiburek 17

ASHRAE Standard 62.2 calls for 7.5 cfm per person plus 0.03 cfm per square foot of conditioned area

Occupancy is deemed to be the number of bedrooms plus one

Building Science Corporation

Joseph Lstiburek 18


ASHRAE Standard 62.2 calls for 7.5 cfm per person plus 0.03 cfm per square foot of conditioned area

Occupancy is deemed to be the number of bedrooms plus one

Outcome is often bad – part load humidity problems, dryness problems, energy problems

Building Science Corporation


Joseph Lstiburek 19



Building Science Corporation

Joseph Lstiburek 20

Recommended Range of Relative Humidity
Above 25 percent during winter
Below 70 percent during summer



Barriers – Technology Dehumidification


Barriers – Cost Exhaust \$150
 Exhaust + Dist \$200
 Supply + Dist \$200
 Spot + Ex/Sup + Dist \$500
 Balanced/ER \$1,250
 Dehumidification \$250 to \$1,250





Building Science Corporation Joseph Lstiburek 23

Tracer Gas Testing
 January 2006


- Tracer gas test of a production house in Sacramento
- 2-story, 4 bedrooms, ~2500 square feet
- Ventilation systems tested: supply and exhaust ventilation, with and without mixing via central air handler

Building Science Corporation Joseph Lstiburek 24








Tuned CONTAM Model



Computer modeling used to replicate field testing (tune the model) and predict performance of systems not tested in the field

Building Science Corporation Joseph Lstiburek 30



Tuned CONTAM Model Applied to Other Systems

Systems Evaluated & Compared:

1. Exhaust ventilation, without central duct system
2. Supply ventilation, without central duct system
3. Exhaust ventilation, with central ducts, standard Tstat
4. Exhaust ventilation, with central ducts, Tstat with timer
5. Supply ventilation, with central ducts, Tstat with timer
6. Fully ducted balanced ventilation system, without central duct system

$$Q(v) = \text{Ventilation Rate}$$

$$Q(\text{fan}) = Q(v) \cdot C(s)$$

$$C(s) = \text{System Coefficient}$$

Airflow Ratios—All Simulations

System Type	Range	Approximate Median
Fully ducted balanced ventilation system, with or without central duct system	1.0	1.0
Non-fully ducted balanced ventilation, with central duct system, and central air handler unit controlled to a minimum runtime of at least 10 minutes per hour	0.9 to 1.1	1.0
Supply ventilation, with central duct system, and central air handler unit controlled to a minimum runtime of at least 10 minutes per hour	1.1 to 1.7	1.25
Exhaust ventilation, with central duct system, and central air handler unit controlled to a minimum runtime of at least 10 minutes per hour	1.1 to 1.9	1.25
Exhaust ventilation, with central duct system, and central air handler unit not controlled to a minimum runtime of at least 10 minutes per hour	1.0 to 1.8	1.5
Supply ventilation, without central duct system	1.4 to 1.9	1.75
Exhaust ventilation, without central duct system	1.3 to 2.6	2.0

BSC 01 - 2013 calls for 7.5 cfm per person plus 0.01 cfm per square foot of conditioned area

Occupancy is deemed to be the number of bedrooms plus one

Occupant Rate + Building Rate

$Q(v) = \text{Fan Flow Rate}$
 $Q(\text{fan}) = Q(v) \cdot C(s)$
 $C(s) = \text{System Coefficient}$

Building Science Corporation Joseph Lstiburek 38

Table 4.1
System Coefficient based on system type¹

System Type	Distributed	Not Distributed
Balanced	1.0	1.25
Not Balanced	1.25	1.5

¹ Where there is whole-building air mixing of at least 70% recirculation turnover each hour, the system coefficient may be reduced by 0.25.

Building Science Corporation Joseph Lstiburek 39

BSC 01-2013
Ventilation for New Low-Rise Residential Building
2,000 ft²
3 bedrooms

20 cfm + 30 cfm = 50 cfm

Mixed, Distributed, Balanced (MDB)
37.5 cfm

Not Mixed, Not Distributed, Not Balanced
75 cfm

Building Science Corporation Joseph Lstiburek 40

House
2,000 ft²
3 bedrooms
8 ft. ceiling
Volume: 16,000 ft³

Ventilation Rates			
	.35 ach	93 cfm	
	.30 ach	80 cfm	
	.25 ach	67 cfm	
	.20 ach	53 cfm	
	.15 ach	40 cfm	
	62 - 73	5 cfm/person	20 cfm
		10 cfm/person	40 cfm
	62 - 89	15 cfm/person	60 cfm
		.35 ach	90 cfm
	62.2 - 2010	7.5 cfm/person	50 cfm
		+ 0.01	
	62.2 - 2013	7.5 cfm/person	90 cfm
		+ 0.03	
	BSC 01 - 2013	7.5 cfm/person	37 cfm
		+ 0.01 (MDB)	75 cfm

Building Science Corporation Joseph Lstiburek 41